

**St. Paul's School: 6-month Surveillance  
November 2014**

**414 Food Services**

<b>Location</b>	<b>ACBM</b>	<b>Approximate Quantity</b>	<b>Category</b>	<b>Friable</b>	<b>Condition November 2012 (3 year)</b>	<b>Condition November 2014</b>	<b>Notes</b>
-----------------	-------------	-----------------------------	-----------------	----------------	---	--------------------------------	--------------

**Basement**

Crawlspace	Pipe Fittings	-----	TSI	Yes	MNO	MNO	
------------	---------------	-------	-----	-----	-----	-----	--

**First Floor**

Common Room	Flooring Paper	1,700 sq. ft	Misc.	Yes	n/a	n/a	Materials were removed by ABS during summer of 2012.s
Upper Dining Room	Flooring Paper	3,500 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring.

**Second Floor**

Food Service's Storage Rooms	Flooring Paper	240 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by 12" tiles in half of room.
Men's Locker Room	Flooring Paper	200 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by 12" tiles.
Men's Restroom	Flooring Paper	60 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by 12" tiles.
Women's Locker Room	Flooring Paper	160 sq. ft	Misc.	MNO	MNO	MNO	Material is under wood flooring which has been covered by carpet.
Women's Restroom	Flooring Paper	80 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by 12" tiles.
Breakroom	Flooring Paper	225 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by carpet.
Linen Storage	Flooring Paper	225 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by linoleum.
Corridor	Flooring Paper	100 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered half by carpet and half by 12" tiles.

**Third Floor**

Guest Bath	Flooring Paper	130 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by 12" tiles.
------------	----------------	------------	-------	-----	-----	-----	--

**St. Paul's School: 6-month Surveillance  
November 2014**

**414 Food Services**

Location	ACBM	Approximate Quantity	Category	Friable	Condition November 2012 (3 year)	Condition November 2014	Notes
Resident Bath	Flooring Paper	60 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by newer vinyl flooring.
Corridor	Flooring Paper	360 sq. ft	Misc.	Yes	MNO	MNO	Material is under wood flooring which has been covered by carpet.

**Fourth Floor**

Room 16	Flooring Paper	120 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Room 17	Flooring Paper	110 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Room 18	Flooring Paper	160 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Linen Closet	Flooring Paper	50 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Room 19	Flooring Paper	160 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Room 20	Flooring Paper	140 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Storage by Rm 20 & 21	Flooring Paper	16 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Room 21	Flooring Paper	200 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Corridor	Flooring Paper	300 sq. ft	Misc.	Yes	n/a	MNO	Material is under wood flooring.
Throughout	Other suspect ACBM is present in and on the building that requires further review, testing, assesment and, based on the results modifications to the management plan may be required. In addition, interior and exterior inspection are required prior to any renovation or demolition work.						Possible inaccessible ACBM also.

**Category:** MISC is miscellaneous material; TSI is thermal system insulation; SURF is surfacing material. Categorized in accordance with 40 CFR Part 763.

**Friable:** Yes means that when dry, it can be easily crumbled or pulverized to powder by hand (ceiling tiles, plaster, pipe insulation, etc.). No means it is nonfriable (floor tiles, etc.). MNO means the material was not observed and further review is required.

**Condition:** N/C means no change was observed. N/A means no access was gained during the reinspection. MNO means the material was not observed and further review is required.

Completed By: \_\_\_\_\_ Date: \_\_\_\_\_